

KENTUCKY SERC STORAGE BATTERY POLICY

It shall be the policy of the Kentucky SERC that;

- 1) Those facilities with banks of storage batteries that contain sufficient sulfuric acid to fall within the US EPA guidelines established for determining if the type and amount of material is an EHS shall be required to develop a Tab Q-7 plan.
- 2) Those facilities which store golf carts on a routine basis, and the total of each vehicles individual battery puts the facility within the US EPA guidelines established for determining if the type and amount of material is an EHS, but does not have on site a facility to re-energize the batteries will not be required to develop a Tab Q-7 plan.
- 3) Those facilities which store golf carts on a routine basis, and the total of each vehicles individual battery puts the facility within the US EPA guidelines established for determining if the type and amount of material is an EHS and has on site a facility to re-energize the batteries, shall be required to develop a Tab Q-7 plan.